

Facility Name _____ Inspection Date _____

Contact Name _____ Title _____

Facility Address _____ Phone (____) _____

City _____ State _____ Zip Code _____

Distributor Name _____

Distributors KSFM permit # _____ Agent/Inspector Name _____

RETAIL FIREWORKS INSPECTIONS

(RETAIL STAND FIRE SAFETY FEATURES)

Kansas State Fire Marshal Retail Stand Fireworks Inspection Checklist

Item	Safety Feature	Met	Not Met	Comments
1	Permitted Sale Dates			
2	Illegal Fireworks			
3	Records			
4	Fire Extinguishers			
5	Attendant On Duty			
6	No Smoking Sign			
7	Storage/Gasoline/Liquids			
8	Number of Exits			
9	Egress Travel Distance			
10	Aisle Width			
11	Housekeeping/Damaged Fireworks			

- ♦ *Under K.A.R. 22-6-20, the Kansas State Fire Marshal's Office has adopted NFPA 1124 (2006 edition).

Notes:

Retail Fireworks Checklist Item Information

Item 01 >> 22-6-5. Permitted Sale Dates

Sale of fireworks not permitted before June 27th and not after July 5th

Item 02 >> 22-6-12 Illegal Fireworks

Refer to KSA 31-155, Bottle Rockets and skyrockets are not permitted. If not met notify KSFMO immediately, confiscate fireworks, and complete seized fireworks receipt. Give copy of Kansas Statutes and Regulations sheet to retail stand representative.

Item 03 >> 22-6-18 Records/Inventory Lists/Distributor

Each operator of a temporary retail stand shall maintain a list of what consumer firework items are on the premises, indicating the Kansas licensed distributor from whom those items were purchased.

Item 04 >> 7.3.6.3*; 7.6.2.1* Fire Extinguishers

Two portable fire extinguishers with a minimum rating of 2A.

OR

Fireworks stands less than 200 square feet are only required to have one portable fire extinguisher.

Item 05 >> 7.5.1.2*. Attendant On Duty

Fireworks shall be under supervision of store employee while open to the public.

Item 06 >> 7.3.11.2*. No Smoking Sign

Posted sign reads "FIREWORKS - NO SMOKING". Sign shall be 2in. high on a contrasting background. Posted at each entrance or within 10 feet of every aisle.

Item 07 >> 7.3.12.2*. Storage/Gasoline/Liquids

Must be at least 50 feet from motor vehicle fuel-dispensing station.

Item 08 >> 22-6-20 (a)(3)(D) Number of Exits

Minimum number of exits provided from the retail sales area should be not less than 2 or as determined in NFPA 101 Life Safety Code whichever is greater.

Item 09 >> 7.3.14.2* Egress Travel Distance

Shall be located so that the maximum egress travel distance, measured from the most remote point to an exit along the natural and unobstructed path of egress travel does not exceed 75 ft.

Item 10 >> 7.3.14.3.1.1* Aisle Width

Aisles shall have a minimum clear width of 48 in.

Item 11 >> 7.3.21.5* Housekeeping/Damaged fireworks

Consumer fireworks devices that are damaged shall be removed and not offered for sale.